


TECHNICAL EVALUATION COMMITTEE REPORT


SOLARIZATION 05-KVA


EVALUATION PARAMETERS	MARKS	NAME OF FIRM		
		M/S Green Egde Engineering, Peshawar	M/S Choice International, Peshawar	M/S Atta Muhammad & Brothers DI Khan
Hard Specification	10			
Compliance with tenders manual	5	5	5	5
Brochures of quoted models attached	5	5	5	5
Support Capabilities	10			
After Sale Service (Warranty)	6	6	6	6
List of support Team	2	2	2	2
List of Services Centers	2	2	2	2
Financial Capabilities	10			
Annual Turn Over/Auditable Accounts of the firm	3	3	3	3
Company history in the business	3	3	3	3
Affidavit/undertaking that the firm never been black listed	4	4	4	4
Relevant Experience	10			
Minimum three work orders for the supply of the quoted hardware/equipment (Preferably in government organizations)	10	10	10	4
Demonstration/Test/Trial	60			
Standardization/Proximity of sample to required standards	10	0	10	0
Demonstration/Test/Trial	50	0	40	0
Total Marks	100	40	90	
Remarks (if any)		Under Specification Low MPPT rating and No Customized Rack		No Sample

Note: Main Components of Solarization were checked however, an undertaking was taken from each bidder except M/S Atta Muhammad & Brothers DI Khan, that successful bidder will fulfill complete requirement of Solarization as per specification and also as per site requirements.


SP/CCP
CCP Peshawar
Member


Deputy Director IT
CTD, Peshawar
Member


Engineer Muhammad Ishaq
UET Peshawar
Co-Opted Member


Dr. Abdul Basit
UET Peshawar
Co-Opted Member


Project Director
Safe City Project Peshawar
Chairman